ASSURED AUTOMATION

KAL-D06
Wiring Instructions

Simply attach the 2 wires from the pulse output switch to terminals #2 & #6. Polarity does NOT matter.